



America


CERTIFICATE

No. U10 003364 0023 Rev. 00

Holder of Certificate: **Shanghai PYTES Energy Co., Ltd.**

No. 3492 Jinqian Road
Fengxian District
201406 Shanghai
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

**Batteries
(Rechargeable Li-ion Battery System)**

Tested according to:

UL 1973:2022
CAN/UL 1973:2022

This product was voluntarily tested to the relevant safety requirements referenced on this certificate. It can be marked with the certification mark above. The mark must not be altered in any way. The certificate holder shall not transfer this certificate to third parties. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC 17067. Certification is based on the TÜV SÜD "Testing, Certification, Validation and Verification Regulations (TCVVR)". For Canadian standards TÜV SÜD America Inc. is accredited by the Standards Council of Canada to ISO/IEC 17065.

Test report no.:

64280236038401

Date, 2024-06-18

(Harry Zhang)



America

CERTIFICATE

No. U10 003364 0023 Rev. 00

Model(s):
 HV48100 BMU-5
 HV48100 BMU-6
 HV48100 BMU-7
 HV48100 BMU-8
 HV48100 BMU-9
 HV48100 BMU-10
 HV48100 BMU-11
 HV48100 BMU-12
 HV48100 BMU-13
 HV48100 BMU-14
 HV48100 BMU-15

Brand Name(s): PYTES


Parameters:

Nominal voltage:	HV48100 BMU-5: 256Vd.c. HV48100 BMU-6: 307.2Vd.c. HV48100 BMU-7: 358.4Vd.c. HV48100 BMU-8: 409.6Vd.c. HV48100 BMU-9: 460.8Vd.c. HV48100 BMU-10: 512Vd.c. HV48100 BMU-11: 563.2Vd.c. HV48100 BMU-12: 614.4Vd.c. HV48100 BMU-13: 665.6Vd.c. HV48100 BMU-14: 716.8Vd.c. HV48100 BMU-15: 768Vd.c.
Rated capacity:	100Ah