



# Ground Fault Breakers

## System Components and Accessories



### Features:

- Ground fault detection and interruption is required by the NEC as a safety precaution
- Ground fault protection for one, two and four PV array systems
- Front panel mount with stud terminals on the back
- Ring terminals required

## Ground Fault Breakers Specifications

02/2019

Model	Description	Terminals	Width (in/cm)
<b>PNL-GFDI-80</b>	PV ground-fault detector interrupter, 80A 150VDC single pole panel mount	1/4 inch stud	1.51 / 3.85
<b>PNL-GFDI-80D</b>	PV ground-fault detector interrupter, 80A 150VDC two pole panel mount	1/4 inch stud	2.26 / 5.73
<b>PNL-GFDI-80Q</b>	PV ground-fault detector interrupter, 80A 150VDC four pole panel mount	1/4 inch stud	3.78 / 9.59

Preliminary specifications are subject to change.

**980-0055-01-00 REV A**

[www.outbackpower.com](http://www.outbackpower.com)

OutBack reserves the right to make changes to the products and information contained in this document without notice.  
Copyright © 2019 OutBack Power. All Rights Reserved. OutBack is a registered trademark of Alpha Technologies Services, Inc.